

# Water Authority of Dickson County

## Local Limits Table

POLLUTANT	JONES CREEK		FAIRVIEW WWTP		WHITE BLUFF	
	MONTHLY AVERAGE LIMIT mg/L	DAILY MAX LIMIT mg/L	MONTHLY AVERAGE LIMIT mg/L	DAILY MAX LIMIT mg/L	MONTHLY AVERAGE LIMIT mg/L	DAILY MAX LIMIT mg/L
Biochemical Oxygen Demand (BOD)	---	1500	---	1500	---	1500
Total Suspended Solids (TSS)	---	1750	---	1750	---	1750
Ammonia-Nitrogen (NH3)	---	100	---	100	---	100
Oil & Grease (O/G)	---	200	---	200	---	200
1,1,1 Trichloroethane	0.3	0.45	0.25	0.375	0.3	0.45
1,2, trans Dichloroethylene	0.006	0.009	0.004	0.006	0.015	0.0225
Arsenic	0.6	0.9	0.46	0.69	0.046	0.069
Benzene	0.004	0.006	0.003	0.0045	0.003	0.0045
Cadmium (Cd)	0.02	0.03	0.003	0.0045	0.002	0.003
Carbon Tetrachloride	0.11	0.165	0.007	0.0105	0.007	0.0105
Chloroform	0.14	0.21	0.08	0.12	0.087	0.1305
Chromium (Cr) III	34	51	4.1	6.15	25	37.5
Chromium (Cr) Total	1	1.5	1	1.5	1	1.5
Chromium (Cr) VI	0.45	0.675	0.17	0.255	0.151	0.2265
Copper (Cu)	1.29	2.8	1.88	2.82	1.08	1.62
Cyanide (Cn)	0.03	0.045	0.06	0.09	0.012	0.018
Ethylbenzene	0.02	0.03	0.016	0.024	0.016	0.024
Lead (Pb)	0.52	0.78	0.23	0.345	0.23	0.345
Mercury (Hg)	0.008	0.012	0.001	0.0015	0.001	0.0015
Methylene Chloride	0.09	0.135	0.056	0.084	0.056	0.084
Naphthalene	0.01	0.015	0.001	0.0015	0.001	0.0015
Nickel (Ni)	3.89	5.835	1.5	2.25	1.637	2.4555
Phenols	1.37	2.055	1.37	2.055	1.37	2.055
Phthalates	0.11	0.165	0.07	0.105	0.645	0.9675
Silver (Ag)	0.23	0.345	0.06	0.09	0.065	0.0975
Tetrachloroethylene	0.21	0.315	0.13	0.195	0.137	0.2055
Toluene	0.15	0.225	0.12	0.18	0.122	0.183
Trichloroethylene	0.1	0.15	0.07	0.105	0.071	0.1065
Zinc (Zn)	1.33	1.995	0.5	0.75	0.038	0.057
Selenium	1.5	2.25	1.5	2.25	1.5	2.25